

# 深圳妈湾电力有限公司2017年2月#1机组烟气数据

浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#1机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	机组停运									
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13	2月13日6:53机组启动发电运行									
14	5	5	1834	5.3	71	99.6	1.5	1.5	22	21
15	7	7	1904	5.3	71	99.4	0.9	0.9	22	21
16	7	7	2009	5.5	72	99.4	0.7	0.7	23	22
17	5	5	1853	5.7	71	99.5	2.1	2.0	23	22
18	5	5	1688	5.1	71	99.6	2.7	2.7	23	22
19	4	4	1535	5.2	72	99.6	2.8	2.9	23	22
20	7	7	1940	5.5	72	99.4	2.3	2.2	23	22
21	5	5	1700	5.8	73	99.5	2.1	2.1	23	22
22	4	4	2134	5.4	72	99.5	2.1	2.0	23	22
23	4	3	1678	6.0	71	99.6	2.1	2.2	23	23
24	3	3	1505	6.0	71	99.7	2.3	2.3	24	23
25	7	7	1744	5.4	70	99.4	2.2	2.1	24	23
26	6	6	1798	5.5	70	99.5	2.0	2.0	25	24
27	4	4	1596	5.2	70	99.7	2.0	2.1	27	26
28	3	3	1434	5.5	70	99.7	1.9	2.0	27	27
最大值	7	7	2134	6.0	73	99.7	2.8	2.9	27	27
最小值	3	3	1434	5.1	70	99.4	0.7	0.7	22	21
平均	5	5	1757	5.5	71	99.5	2.0	2.0	23	23

制表人：李中坚

审核人：吴兴远

企业负责人：王成



# 深圳妈湾电力有限公司2017年2月#2机组烟气数据

浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#2机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	机组停机									
2	2月2日4: 52机组启动发电									
3	10	10	2149	5.5	73	98.7	4.0	4.0	24	23
4	10	10	1924	5.7	71	98.8	3.7	3.7	22	22
5	10	10	2153	5.4	71	98.8	5.2	5.0	27	26
6	10	10	2090	5.6	72	98.9	4.1	4.0	24	24
7	10	10	1924	5.6	70	99.0	2.6	2.5	19	18
8	10	10	1979	5.6	71	99.0	1.9	1.9	19	19
9	11	11	1836	5.9	67	98.9	2.5	2.5	19	19
10	12	12	1957	5.7	68	98.7	2.4	2.4	21	20
11	12	12	2022	5.7	68	98.6	2.6	2.5	21	20
12	12	12	2052	5.3	70	98.6	2.5	2.6	19	18
13	14	14	2014	5.7	70	98.5	2.1	2.5	22	22
14	16	15	2257	5.4	73	98.3	1.5	1.5	24	23
15	16	15	2215	5.4	71	98.4	0.9	0.9	24	23
16	16	15	2228	5.2	73	98.4	0.7	0.7	29	27
17	14	13	2135	5.3	73	98.4	2.1	2.0	30	29
18	14	13	2042	5.5	72	98.6	2.7	2.7	22	21
19	15	15	1932	5.9	70	98.3	2.8	2.9	26	26
20	19	18	2192	5.2	73	98.1	2.3	2.2	29	28
21	18	17	2183	5.6	72	98.1	2.1	2.1	29	28
22	16	15	2181	5.2	71	98.0	2.1	2.0	27	26
23	15	14	2027	5.5	69	98.3	2.1	2.2	35	34
24	14	14	1912	5.7	67	98.2	2.3	2.3	30	29
25	15	14	2284	5.1	70	98.4	2.2	2.1	30	29
26	16	15	2208	5.4	70	98.5	2.0	2.0	30	29
27	18	17	1910	5.8	70	98.2	2.0	2.1	29	29
28	17	17	1711	6.1	68	98.1	1.9	2.0	27	27
最大值	19	18	2284	6.1	73	99.0	5.2	5.0	35	34
最小值	10	10	1711	5.1	67	98.0	0.7	0.7	19	18
平均	14	13	2058	5.5	70	98.5	2.4	2.4	25	24

制表人：李中坚

审核人：吴兴远

企业负责人：王成

# 深圳妈湾电力有限公司2017年2月#3机组烟气数据

浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#3机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	机组停运									
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22	2月22日9:45机组启动运行									
23	8	8	1599	5.3	70	99.1	3.0	2.9	30	29
24	8	7	1547	5.2	67	99.1	2.9	2.8	28	26
25	11	9	1593	3.9	69	99.0	2.9	2.7	33	29
26	11	10	1581	4.3	70	99.0	3.2	3.0	26	24
27	10	9	1555	5.1	70	99.1	3.0	3.0	21	20
28	7	7	1505	6.3	68	99.2	2.8	3.0	17	17
最大值	11	10	1599	6.3	70	99.2	3.2	3.0	33	29
最小值	7	7	1505	3.9	67	99.0	2.8	2.7	17	17
平均	9	9	1563	5.0	69	99.1	3.0	2.9	26	24

制表人：李中坚

审核人：吴兴远

企业负责人：王成

