

广深公司2018年2月#2机组烟气数据

浓度单位 (mg/Nm ³) 烟气量单位 : 万立方米/天									
#2机组脱硫系统出口									
日期	二氧化硫		烟气量	氧量%	脱硫效率%	颗粒物		氮氧化物	
	标态	折算				标态	折算	标态	折算
1	18.00	18.84	2142.65	6.74	99.02	5.80	6.12	38.20	40.14
2	19.00	20.32	2004.18	7.14	99.16	5.80	6.27	36.40	39.41
3	15.00	16.34	2070.00	7.16	99.36	5.80	6.31	37.20	40.30
4	14.00	14.53	2045.74	7.06	99.18	5.70	6.12	37.20	40.02
5	14.00	15.64	2013.59	7.40	99.08	5.70	6.24	36.00	39.66
6	14.00	16.06	1930.65	7.98	99.05	5.70	6.59	35.50	40.90
7	16.00	18.11	1955.73	7.69	99.08	5.70	6.47	35.40	39.90
8	11.00	13.21	1760.13	8.36	99.38	5.60	6.66	32.80	38.90
9	14.00	15.03	2048.76	7.15	99.14	5.90	6.41	36.90	39.93
10	13.00	15.79	1783.78	8.78	99.02	5.90	7.23	31.60	38.75
11	16.00	17.43	2029.61	7.28	99.09	5.90	6.44	38.30	41.86
12	14.00	16.41	1858.10	8.18	99.04	6.00	7.03	34.70	40.57
13	11.00	12.76	1963.46	7.81	99.00	6.20	7.01	35.80	40.73
14	10.00	10.81	1945.71	7.61	99.00	6.70	7.46	35.40	39.64
15	13.00	14.99	1919.45	8.02	99.04	6.80	7.91	34.00	39.30
16	10.00	11.88	1850.76	8.16	99.25	6.60	7.70	33.30	38.84
17	13.00	15.73	1745.91	8.28	99.21	6.30	7.41	34.20	40.33
18	12.00	13.92	1773.41	8.28	99.17	6.30	7.42	33.40	39.36
19	10.00	11.49	1792.34	8.19	99.19	6.30	7.39	34.60	40.50
20	11.00	12.94	1790.86	8.41	98.97	6.50	7.78	33.40	39.77
21	10.00	11.50	1808.54	8.16	98.90	6.50	7.63	34.00	39.76
22	9.00	9.97	1903.87	8.14	98.92	6.10	7.14	33.50	39.09
23	14.00	16.84	1805.33	8.42	98.25	5.90	7.08	33.60	40.12
24	14.00	15.42	1841.91	7.86	98.66	6.20	7.13	34.60	39.48
25	17.00	19.82	1789.23	8.50	98.83	5.90	7.09	34.10	40.92
26	11.00	13.75	1801.70	8.63	99.19	5.90	7.19	33.30	40.42
27	11.00	12.72	1815.86	8.48	99.13	6.00	7.18	34.10	40.84
28	16.00	18.30	1865.73	7.78	98.98	6.20	7.05	36.30	41.19
平均值	13.21	15.02	1894.89	7.92	99.05	6.07	6.98	34.92	40.02
最大值	19.00	20.32	2142.65	8.78	99.38	6.80	7.91	38.30	41.86
最小值	9.00	9.97	1745.91	6.74	98.25	5.60	6.12	31.60	38.75
总和			53056.99	/	/	/	/	/	/

上报单位 (盖章) : 广深沙角B电力有限公司 负责人:  报告人:  报告日期: 2018.3.6

沙角B火力发电厂

